



Ground Jumper Clamps



- Cast of High Strength, High Conductivity Copper Alloy
- Stainless Steel Hardware
- Make Connections between Aluminum or Galvanized Steel and Copper or Copper Bonded Steel Wires
- Bow Design Spring Action Maintains Positive Clamping Force
- Wrap-Around Design Secures Conductor

DIMENSIONS = INCHES

CAT. NO.	FINISH	CONDUCTOR RANGE		CONDUCTOR DIAMETER	BOLT MATERIAL	BOX QTY
		MIN	MAX			
91922	TIN PLATED	6 SOL	1/0 STR	.162 - .373	STAINLESS	25

Transformer Ground Connectors



- For Transformers with 1/2"-13 Tapped Hole
- High Strength High Conductivity Copper Alloy
- Stainless Steel Nuts & Lock Washer

CAT. NO.	CONDUCTOR RANGE		BOX QTY
	MAX	MIN	
91902	1 STR	10 SOL	25
91904	2/0 STR	8 SOL	25
91906	250 MCM	6 SOL	5

Table 250.66 Grounding Electrode Conductor for Alternating-Current Systems

Size of Largest Ungrounded Service-Entrance Conductor or Equivalent Area for Parallel Conductors ^a (AWG/kcmil)		Size of Grounding Electrode Conductor (AWG/kcmil)	
Copper	Aluminum or Copper-Clad Aluminum	Copper	Aluminum or Copper-Clad Aluminum ^b
2 or smaller	1/0 or smaller	8	6
1 or 1/0	2/0 or 3/0	6	4
2/0 or 3/0	4/0 or 250	4	2
Over 3/0 through 350	Over 250 through 500	2	1/0
Over 350 through 600	Over 500 through 900	1/0	3/0
Over 600 through 1100	Over 900 through 1750	2/0	4/0
Over 1100	Over 1750	3/0	250

Notes:

1. Where multiple sets of service-entrance conductors are used as permitted in 230.40, Exception No. 2, the equivalent size of the largest service-entrance conductor shall be determined by the largest sum of the areas of the corresponding conductors of each set.

2. Where there are no service-entrance conductors, the grounding electrode conductor size shall be determined by the equivalent size of the largest service-entrance conductor required for the load to be served.

^aThis table also applies to the derived conductors of separately derived ac systems.

^bSee installation restrictions in 250.64(A).

Table 250.122 Minimum Size Equipment Grounding Conductors for Grounding Raceway and Equipment

Rating or Setting of Automatic Overcurrent Device in Circuit Ahead of Equipment, Conduit, etc., Not Exceeding (Amperes)	Size (AWG or kcmil)	
	Copper	Aluminum or Copper-Clad Aluminum [*]
15	14	12
20	12	10
30	10	8
40	10	8
60	10	8
100	8	6
200	6	4
300	4	2
400	3	1
500	2	1/0
600	1	2/0
800	1/0	3/0
1000	2/0	4/0
1200	3/0	250
1600	4/0	350
2000	250	400
2500	350	600
3000	400	600
4000	500	800
5000	700	1200
6000	800	1200

Note: Where necessary to comply with 250.4(A)(5) or (B)(4), the equipment grounding conductor shall be sized larger than given in this table.

^{*}See installation restrictions in 250.120.