MORRIS

cULus LISTED | 5 YEAR WARRANTY

FEATURES:

- For use with Panels, Troffers, Strips, Wraps & Vaportight Fixtures
- 76501: 15W
- 76502: 25W
- 120V AC (170V DC Line Side Wiring)
- Runs for 90 Minutes in Emergency Mode

- No load side DC wiring necessary - fast and simple
- cULus Listed
- Order Qty of 1 = 1 Piece

CAUTION:

1. The emergency LED driver must connect to 0/1-10V dimming wires (DIM+, DIM-) of the fixture if the LED fixture power exceeds the EM LED driver.

2. In emergency mode, double-click the test switch to turn off the current emergency status.

76501-76502 - LINE SIDE EMERGENCY BACKUP

15W/25W

MORRIS

TECHNICAL SPECIFICATIONS:

MODEL NO.	76501	76502
Input Voltage	100-347Vac, 50/60Hz	100-347Vac, 50/60Hz
Input Current	0.1A max	0.1A max
Input Power	12W max	12W max
Ouput Voltage	170V DC	170V DC
Output Power	15W	25W
Application	① ≤150W(0/1-10V Dimmable Fixture) ② ≤15W LED Lamps without dimming function	① ≤150W(0/1-10V Dimmable Fixture) ② ≤25W LED Lamps without dimming function
Ambient Temperature	41°F - 122°F	41°F - 122°F

Wiring Diagram

Wiring 1 : For LED Driver With Input Power Higher Than Emergency Output Power

0/1-10V Dimmable LED Driver + Dimmer Switch

Emergency Driver Dim+(Green) , Driver Dim-(Yellow) Have to connect with LED driver DIM+ and DIM-

MORRIS

Wiring 2 : *For LED Driver With Input Power Higher Than Emergency Output Power*

0/1-10V Dimmable LED Driver + Wall Switch
Emergency Driver Dim+(Green) , Driver Dim-(Yellow) Have to connect with LED driver DIM+ and DIM-

Wiring 3 : For LED Driver With Input Power Less Than Emergency Output Power
NON Dimmable LED Driver

⚠️ **CAUTION**

- This product must be installed by a licensed electrician only, abiding by all local and national electrical codes.

- Before installation, make sure the AC power to the fixture and EM backup is turned off.

- Verify that the fixture and this EM backup are compatible.

- It is recommended to charge the battery at least every 6 months to prevent over discharge.

- Do not let the power supply cords touch hot surfaces.

- Do not mount this EM backup near gas or electric heaters.